

CERTIFICATE OF CONFORMITY

This Certificate is issued to

REC SOLAR PTE LTD

(UEN No.: 200723409E)

20 Tuas South Avenue 14, Logos Tuas Logistics Hub, Singapore 637312

For Product Certification Scheme: Type 2

Product : Solar Photovoltaic (PV) Roof-Mounted Module

Brand : REC Solar

Model : RECxxxAA Pure-RX (where xxx = 420 – 470)

Country of Origin : Singapore

**Product Details : Monocrystalline silicon photovoltaic module
Maximum System Voltage: 1000V
Dimension: 1728mm x 1205mm x 30mm
No. of Cells: 88 half-cut monocrystalline cells
Fire Rating: Class C**

which has complied with the requirements of the scheme based on the following:

STANDARD(S)


IEC 61730-2: 2016

TEST REPORT(S)

UL Test Report No.: 4790537955

UL Service Request Letter Ref No.: 58868346.1480915

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Fiona Leong (Ms)

Program Manager

SETSCO Services Pte Ltd

531 Bukit Batok Street 23,

Singapore 659547

Certificate No

FSP-2023-1456

Date of Issue

02/11/2023

Date of Last Revision

26/12/2023

Date of Expiry

01/11/2028

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

CERTIFICATE OF CONFORMITY

This Certificate is issued to

REC SOLAR PTE LTD

(UEN No.: 200723409E)

20 Tuas South Avenue 14, Logos Tuas Logistics Hub, Singapore 637312

For Product Certification Scheme: Type 2

Product : Solar Photovoltaic (PV) Roof-Mounted Module

Brand : REC Solar

Model : RECxxxAA Pure-R

Country of Origin : Singapore

Product Details : Monocrystalline silicon photovoltaic module

Maximum System Voltage: 1000V

Dimension: 1730 x 1118 x 30 mm

No. of Cells: 80 half-cut monocrystalline cells

Fire Rating: Class C

which has complied with the requirements of the scheme based on the following:

STANDARD(S) TEST REPORT(S)

IEC 61730-2: 2016

UL Test Report No.: 4790537955

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23,
Singapore 659547

Certificate No
FSP-2022-1299

Date of Issue
12/12/2022

Date of Expiry
11/12/2027

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

CERTIFICATE OF CONFORMITY

This Certificate is issued to

REC SOLAR PTE LTD

(UEN No.: 200723409E)

20 Tuas South Avenue 14, Logos Tuas Logistics Hub, Singapore 637312

For Product Certification Scheme: Type 2

Product : Solar Photovoltaic (PV) Roof-Mounted Module

Brand : REC Solar

**Model : RECxxxTP5 (where xxx = 395 - 415)
RECxxxTP5 Black (where xxx = 390 - 410)**

Country of Origin : Singapore

**Product Details : Monocrystalline silicon photovoltaic module
Maximum System Voltage: 1000V
Dimension: 1899 x 1040 x 30 mm
No. of Cells: 132 half-cut monocrystalline cells
Fire Rating: Class C**

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
IEC 61730-2: 2016	UL Test Report No.: 4790712083 UL Test Report No.: 4790712068 VDE Test Report No.: TRPVM-2022-40598-1

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23,
Singapore 659547

Certificate No
FSP-2023-1323

Date of Issue
24/02/2023

Date of Expiry
23/02/2028

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

CERTIFICATE OF CONFORMITY

This Certificate is issued to

REC SOLAR PTE LTD

(UEN No.: 200723409E)

20 Tuas South Avenue 14, Singapore 637312

For Product Certification Scheme: Type 2

Product : Solar Photovoltaic (PV) Roof-Mounted Module

Brand : REC Solar

Model : RECxxxAA Pure (where xxx = 385 – 410, in steps 5)


Country of Origin : Singapore

**Product Details : Heterojunction monocrystalline silicon terrestrial photovoltaic module.
Maximum system voltage: 1000 VDC
No. of Cells: 132 cells
Dimension: 1821mm x 1016mm x 30mm
Fire Rating: Class C**

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
IEC 61730-2: 2016	VDE Test Report No.: TRPVM-2021-40119-1

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No
FSP-2021-1122

Date of Issue
19/08/2021

Date of Expiry
18/008/2026

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

CERTIFICATE OF CONFORMITY

This Certificate is issued to

REC SOLAR PTE LTD
(UEN No.: 200723409E)
20 Tuas South Avenue 14, Singapore 637312

For Product Certification Scheme: Type 2

Product : Solar Photovoltaic (PV) Roof-Mounted Module
Brand : REC Solar
Model : RECxxxTP4 (where xxx = 355-380 in steps of 5)
Country of Origin : Singapore
Product Details : Monocrystalline silicon terrestrial photovoltaic module.
Maximum system voltage: 1000 VDC
No. of Cells: 120 cells
Dimension: 1755mm x 1040mm x 30mm
Fire Rating: Class C

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
IEC 61730-2: 2016	VDE Test Report No.: TRPVM-2021-40198-1 VDE Test Report No.: TRPVM-2021-40348-1

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Dixon Ng (Mr)
Program Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No
FSP-2021-1121

Date of Issue
19/08/2021

Date of Expiry
18/08/2026

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.

CERTIFICATE OF CONFORMITY

This Certificate is issued to

REC SOLAR PTE LTD

(UEN No.: 200723409E)

20 Tuas South Avenue 14, Logos Tuas Logistics Hub, Singapore 637312

For Product Certification Scheme: Type 2

Product : Solar Photovoltaic (PV) Roof-Mounted Module

Brand : REC Solar

Model : RECxxxAA Pure 2 (where xxx = 400 – 430)

Country of Origin : Singapore

**Product Details : Monocrystalline silicon photovoltaic module
Maximum System Voltage: 1000V
Dimension: 1865mm x 1040mm x 30mm
No. of Cells: 132 half-cut monocrystalline cells
Fire Rating: Class C**

which has complied with the requirements of the scheme based on the following:

STANDARD(S) TEST REPORT(S)

IEC 61730-2: 2016

UL Test Report No.: 4790537955

Detailed configuration and installation shall be referenced to the certified report(s) stated above.



Fiona Leong (Ms)
Program Manager
SETSCO Services Pte Ltd
531 Bukit Batok Street 23,
Singapore 659547

Certificate No

FSP-2023-1438

Date of Issue

02/11/2023

Date of Expiry

01/11/2028

This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com

The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.